



BIOLOGICAL CONSULTING SERVICES
OF NORTH FLORIDA, INC.

2019-09-26

Ulrich Weise
Weise Water GmbH
Gewerbehof Nord, TO1, Tor 2
Eduard-Maurer- Str. 13
16761 Hennigsdorf, Germany

+49 (0) 330 203 1455
u.weise@weise-water.de
Client ID: AQQA bag 1, AQQA bag 2

BCS ID: 1909302, 1909303

Project Name: WW09232019 E.Coli 11229 Initial Filtration Efficacy Testing

Dear Ulrich Weise,

We have completed the filtration efficacy study on the submitted units as outlined below. The contaminant species, study conditions, and water parameters utilized were based on client's request and adaptation of the guidance documents and protocols listed below:

Validation of Water Purifier Microbiological Filtration Efficacy: Screening of initial performance as per client request; BCS SOP-F1 (ISO17025 accredited)

Report Conclusion: Study completed as per clients request.

Following, you will find our report on the results of the study conducted on the referenced samples. Should you have any questions, please do not hesitate to contact me.

Sincerely,

George Lukasik, Ph.D.
Laboratory Director

Page 1 of 8

Final Report BCS ID 1909302, 1909303 Revision #0 MV 09.26.2019

Client: Weise Water

Project: WW09232019 E.Coli 11229 Initial Filtration Efficacy Testing
BCS LABORATORIES, INC. — GAINESVILLE
4609 NW 6TH STREET, STE. A, GAINESVILLE, FLORIDA 32609
TEL. (352) 377-9272, FAX. (352) 377-5630
WWW.MICROBIOSERVICES.COM

FL DOH #E82924, ISO/IEC 17025:2017 L2422 (ANAB), PA DEP# 68-03950, EPA# FLO1147
THIS REPORT SHALL NOT BE REPRODUCED, EXCEPT IN FULL, WITHOUT THE WRITTEN CONSENT OF BCS LABORATORIES



Analysis: *E. coli* Filtration Efficacy

Test Water: General Test Water I

Analysis Method: Spread Plating (Standard Method 9215)

Test Point: Initial Performance

Test Point Conclusion: PASS

Challenge Date: 2019-09-24 Challenge Analysts: Molly Vise, B.S.

Initial Pres. (PSI): N/A Temp: 24.8 C

pH: 8.2 Turbidity: 0.11NTU TOC: 0.98 ppm TDS: 213.3 ppm Hardness: 115.0ppm

Alkalinity: 82.0ppm Total Chlorine: 0.02ppm Polyphosphate (as phosphorus): N/A

Influent Conc: 4.1E+05 cfu/mL Ambient Temp: 24.9C

Analysis Date: 2019-09-24 Analysts: Molly Vise, B.S.

Test Notes: Challenge water was allowed to filter through the test units by gravity. *E. coli* bacteria was not detected in units' effluent water. Units effectively filtered bacterial contamination from test water when tested as described in report notes.

BCS Sample ID 1: 1909302	Client ID 1: AQQA bag 1	Flow Rate 1: 0.11 LPM	Press 1(psi): N/A
Eff Conc 1: <3.0E-01 cfu/mL	% Reduct 1: >99.99993	Log10 Reduct 1:	>6.1
BCS Sample ID 2: 1909303	Client ID 2: AQQA bag 2	Flow Rate 2: 0.11 LPM	Press 2(psi): N/A
Eff Conc 2: <3.0E-01 cfu/mL	% Reduct 2: >99.99993	Log10 Reduct 2:	>6.1

Client: Weise Water

Project: WW09232019 E.Coli 11229 Initial Filtration Efficacy Testing

BCS LABORATORIES, INC. — GAINESVILLE
4609 NW 6TH STREET, STE. A, GAINESVILLE, FLORIDA 32609
TEL. (352) 377-9272, FAX. (352) 377-5630

WWW.MICROBIOSERVICES.COM

FL DOH #E82924, ISO/IEC 17025:2017 L2422 (ANAB), PA DEP# 68-03950, EPA# FLO1147
THIS REPORT SHALL NOT BE REPRODUCED, EXCEPT IN FULL, WITHOUT THE WRITTEN CONSENT OF BCS LABORATORIES



Project: WW09232019 E.Coli 11229 Initial Filtration Efficacy Testing

Date Received: 2019-09-23 13:33

Test Start Date: 2019-09-24

Test End Date: 2019-09-24

System Type: 5 Liter Membrane Water Filter Bag; Gravity filtration

Est. Capacity: N/A

Performance Indicating Device: N/A

Batch Volume: N/A

Batch, number per day: N/A

Test Cycle (min): N/A

Cycle On/Off (%): N/A

Restricted Flow Rate: No

Test Duration (hr per day): N/A

Test Conditioning: 5L of Dechlorinated Tap Water

Report Notes:

The provided water purifier units were received from the study sponsor and given the BCS identifiers 1909301-303. Three units were received and two were randomly chosen for the study. The test was conducted to determine the units' initial use filtration efficacy. Each unit consisted of a clear plastic bag that contained an internal membrane. Each unit, was conditioned by filling with 5 Liters of General Test Water 1 (GTW1, NSF P231; dechlorinated municipal water). The water was allowed to flow through the unit. Following cessation of flow, the challenge was initiated. Briefly, the indicated challenge species was added to 10 Liters of GTW1. The water was homogenized and 5 Liters were transferred into each bag. Following the passage of 500mL of test water, a 1 Liter sample of each filter bag's effluent was collected in a sterile container. A sample of the influent test water was collected at the start and end of the challenge. Influent and effluent sample analysis was conducted in triplicate at minimum. All water characteristics, test parameters, and challenge species analysis were performed as per standard laboratory operating procedure. Study & analysis was conducted as per laboratory's accredited ISO17025:2017 methodology: E.coli was analyzed as per SM 9215C (APHA 2012), turbidity as per SM2130B, pH as per SM4500HB, TDS as per SM2540, chlorine as per SM4500-Cl G, & hardness as per SM2340C (if needed). All analysis was conducted using calibrated and/or validated instruments to traceable standards (NIST). All Quality Control (QC) data were within acceptance range. No general environmental conditions are specified in the standard or have been identified that could affect the test results or measurements. End of Report Notes.

Client: Weise Water

Project: WW09232019 E.Coli 11229 Initial Filtration Efficacy Testing

BCS LABORATORIES, INC. — GAINESVILLE

4609 NW 6TH STREET, STE. A, GAINESVILLE, FLORIDA 32609

TEL. (352) 377-9272, FAX. (352) 377-5630

WWW.MICROBIOSERVICES.COM

FL DOH #E82924, ISO/IEC 17025:2017 L2422 (ANAB), PA DEP# 68-03950, EPA# FLO1147
THIS REPORT SHALL NOT BE REPRODUCED, EXCEPT IN FULL, WITHOUT THE WRITTEN CONSENT OF BCS LABORATORIES



*I certify that I have examined and I am familiar with the information submitted herein. The results pertain only to the sample(s) tested, associated identifier #(s), and condition at receipt. Based on my inquiry of the individuals responsible for the analysis, I believe the data to be true, accurate, and complete. Unit descriptions and names were obtained from the submitted documents. The analysis was authorized and commissioned by the client or client's representative. The resulting data are representative of the analysis conducted on the collected samples and it's/their condition at the time of analysis. The data provided is strictly representative of the study conducted under laboratory conditions using the material/samples/articles provided by the client (or client's representative) and it's (their) condition at the time of test following receipt. The data obtained may not be representative or indicative of a real-life process and/or application. The sample(s) were analyzed in accordance with the appropriate method, however due to the inherent limitations of methods, microorganisms may avoid detection. BCS Laboratories offers no express or implied warranties concerning the quality, safety, and/or purity of any sample, batch, source, or the process they are derived from. Quality assurance controls were performed as outlined in the method and as per Good Laboratory Practices. Analyses were performed in accordance with laboratory practices and procedures set-forth by ISO 17025-2005 and NELAP/TNI accreditation standards unless otherwise noted. BCS makes no express or implied warranty regarding the ownership, merchantability, safety or fitness for a particular purpose of any such property or product.

Signature of Laboratory Director/Authorized Rep.  Date: 2019-09-26

Client: Weise Water

Project: WW09232019 E.Coli 11229 Initial Filtration Efficacy Testing

BCS LABORATORIES, INC. — GAINESVILLE
4609 NW 6TH STREET, STE. A, GAINESVILLE, FLORIDA 32609
TEL. (352) 377-9272, FAX. (352) 377-5630

WWW.MICROBIOSERVICES.COM

FL DOH #E82924, ISO/IEC 17025:2017 L2422 (ANAB), PA DEP# 68-03950, EPA# FLO1147
THIS REPORT SHALL NOT BE REPRODUCED, EXCEPT IN FULL, WITHOUT THE WRITTEN CONSENT OF BCS LABORATORIES



Pictures:



Client: Weise Water

Project: WW09232019 E.Coli 11229 Initial Filtration Efficacy Testing

BCS LABORATORIES, INC. — GAINESVILLE

4609 NW 6TH STREET, STE. A, GAINESVILLE, FLORIDA 32609

TEL. (352) 377-9272, FAX. (352) 377-5630

WWW.MICROBIOSERVICES.COM

FL DOH #E82924, ISO/IEC 17025:2017 L2422 (ANAB), PA DEP# 68-03950, EPA# FLO1147
THIS REPORT SHALL NOT BE REPRODUCED, EXCEPT IN FULL, WITHOUT THE WRITTEN CONSENT OF BCS LABORATORIES



*Balance ID: BL-10	Description: Sartorius Practum Precision Balance
Range of Function: 0-3100 g	Instrument Reporting Limit: 0.01g
Last Service Date: 2019-08-07	Service Due Date: 2020-08-31
Service Type: NIST Calibration	NIST Validation Instrument: External Provided
*pH Meter ID: PH-09	Description: Orion Versa Star Pro Meter w/pH and Conductivity Modules
Range of Function: 0.001-12.000	Instrument Reporting Limit: 0.001
Last Service Date: 2018-09-07	Service Due Date: 2019-09-30
Service Type: Manufacturer OEM	NIST Validation Instrument: NIST Standard Solution
*Conductivity Meter ID: CM-08	Description: Orion Versa Star Pro Meter w/pH and Conductivity Modules
Range of Function: 0.01-2400 ppm	Instrument Reporting Limit: 0.01ppm
Last Service Date: 2018-09-07	Service Due Date: 2019-09-30
Service Type: Manufacturer OEM	NIST Validation Instrument: NIST Standard Solutions
*Alkalinity Meter ID: ALK-04	Description: Alkaline Meter
Range of Function: 10-4000 mg/L	Instrument Reporting Limit: 10 mg/L
Last Service Date: 2018-07-01	Service Due Date: 2019-09-01
Service Type: Manufacturer OEM	NIST Validation Instrument: NIST standard
*Hardness Meter ID: HARD-02	Description: Hach Total Hardness Test Kit 10-4,000 mg/L
Range of Function: 10-4000mg/L	Instrument Reporting Limit: 10 mg/L
Last Service Date: 2019-05-20	Service Due Date: 2020-05-20
Service Type: Validation to NIST	NIST Validation Instrument: NIST Standard solutions
*Turbidity Meter ID: TM-05	Description: Hach Turbidimeter
Range of Function: 0.00-999NTU	Instrument Reporting Limit: 0.01NTU
Last Service Date: 2019-08-29	Service Due Date: 2020-08-29
Service Type: Manufacturer OEM	NIST Validation Instrument: NIST Standard Solutions
*Spectrophotometer ID: SPEC-02	Description: Hach DR 3900 Spectrophotometer Colorimeter
Range of Function: 320-1000nm	Instrument Reporting Limit: 0.01nm
Last Service Date: 2019-09-13	Service Due Date: 2020-09-13
Service Type: Manufacturer service	NIST Validation Instrument: NIST Standard Solutions
Incubator ID: I-20	Description: Thermo Fisher Forma 29 cu. ft. Reach-In Incubator
Range of Function: 10-65C	Instrument Reporting Limit: 0.1C
Last Service Date: 2018-08-31	Service Due Date: 2019-09-30
Service Type: Annual Service	NIST Validation Instrument: IR-09

Client: Weise Water

Project: WW09232019 E.Coli 11229 Initial Filtration Efficacy Testing

BCS LABORATORIES, INC. — GAINESVILLE
 4609 NW 6TH STREET, STE. A, GAINESVILLE, FLORIDA 32609
 TEL. (352) 377-9272, FAX. (352) 377-5630

WWW.MICROBIOSERVICES.COM

FL DOH #E82924, ISO/IEC 17025:2017 L2422 (ANAB), PA DEP# 68-03950, EPA# FLO1147
 THIS REPORT SHALL NOT BE REPRODUCED, EXCEPT IN FULL, WITHOUT THE WRITTEN CONSENT OF BCS LABORATORIES



**Flow Meter ID 1: N/A	Description:		
Range of Function:		Instrument Reporting Limit:	
Last Service Date:		Service Due Date:	
Service Type:		NIST Validation Instrument:	
**Flow Meter ID 2: N/A	Description:		
Range of Function:		Instrument Reporting Limit:	
Last Service Date:		Service Due Date:	
Service Type:		NIST Validation Instrument:	
**Flow Meter ID 3: N/A	Description:		
Range of Function:		Instrument Reporting Limit:	
Last Service Date:		Service Due Date:	
Service Type:		NIST Validation Instrument:	
Microscope ID: N/A	Description:		
Range of Function:		Instrument Reporting Limit:	
Last Service Date:		Service Due Date:	
Service Type:		NIST Validation Instrument:	
Refrigerator ID: FR-11	Description: Migali B Series Glass Door Refrigerator		
Range of Function: 1-8C		Instrument Reporting Limit: N/A	
Last Service Date: 2018-08-28		Service Due Date: 2019-09-30	
Service Type: Annual Service		NIST Validation Instrument: External Provided	
Centrifuge ID: C-12	Description: Eppendorf centrifuge w/ cell culture package		
Range of Function: 0-4400 RPM		Instrument Reporting Limit: 1 RPM	
Last Service Date: 2018-08-28		Service Due Date: 2019-09-30	
Service Type: Annual Service		NIST Validation Instrument: TA-01	
Pressure Source Pump ID: N/A	Description:		
Range of Function:		Instrument Reporting Limit:	
Last Service Date:		Service Due Date:	
Service Type:		NIST Validation Instrument:	
Pressure Meter ID: N/A	Description:		
Range of Function:		Instrument Reporting Limit:	
Last Service Date:		Service Due Date:	
Service Type:		NIST Validation Instrument:	

Client: Weise Water

Project: WW09232019 E.Coli 11229 Initial Filtration Efficacy Testing

BCS LABORATORIES, INC. — GAINESVILLE
 4609 NW 6TH STREET, STE. A, GAINESVILLE, FLORIDA 32609
 TEL. (352) 377-9272, FAX. (352) 377-5630
 WWW.MICROBIOSERVICES.COM

FL DOH #E82924, ISO/IEC 17025:2017 L2422 (ANAB), PA DEP# 68-03950, EPA# FLO1147
 THIS REPORT SHALL NOT BE REPRODUCED, EXCEPT IN FULL, WITHOUT THE WRITTEN CONSENT OF BCS LABORATORIES



Cert. Pressure Meter ID: N/A	Description:	
Range of Function:		Instrument Reporting Limit:
Last Service Date:		Service Due Date:
Service Type:		NIST Validation Instrument:
TOC Analyzer ID: TOC-01	Description: GE M5310C Lab TOC Analyzer	
Range of Function: 40ppb-50ppm		Instrument Reporting Limit: 0.01ppb
Last Service Date: 2019-05-29		Service Due Date: 2020-05-29
Service Type: Manufacuter Cal.		NIST Validation Instrument: NIST Standard Solutions
ICP-MS ID: N/A	Description:	
Range of Function:		Instrument Reporting Limit:
Last Service Date:		Service Due Date:
Service Type:		NIST Validation Instrument:
Thermometer ID: IR-09 NIST	Description: VWR Traceable Infrared Thermometer	
Range of Function: -60-500C		Instrument Reporting Limit: 0.01C
Last Service Date: 2018-04-30		Service Due Date: 2020-04-30
Service Type: Calibration		NIST Validation Instrument: Manufactuer calibration
Timer ID: T-37 Traceable Jumbo Timer		
NIST Expiration Date: 2021-02-19		
*Validated at each day of use using NIST traceable standards. Other major equipment validated quarterly.		
**Validated at each use using traceable volume and time measurements.		
All above equipment with completed fields were used from Test Start Date through Test End Date unless otherwise noted. Service Date indicates PM and/or calibration by accredited service provider. Service Dates reported for latest period. If Last Service Date occurs during study duration, please contact us for the previous period's validation information.		

END OF REPORT

Client: Weise Water

Project: WW09232019 E.Coli 11229 Initial Filtration Efficacy Testing

BCS LABORATORIES, INC. — GAINESVILLE

4609 NW 6TH STREET, STE. A, GAINESVILLE, FLORIDA 32609

TEL. (352) 377-9272, FAX. (352) 377-5630

WWW.MICROBIOSERVICES.COM

FL DOH #E82924, ISO/IEC 17025:2017 L2422 (ANAB), PA DEP# 68-03950, EPA# FLO1147
THIS REPORT SHALL NOT BE REPRODUCED, EXCEPT IN FULL, WITHOUT THE WRITTEN CONSENT OF BCS LABORATORIES

